

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-1209:206

**CATEGORY:** Audible Devices

**LISTEE:** System Sensor, 3825 Ohio Ave., St Charles, IL 60174  
Contact: Andrej Nikolic (630) 377-6674

**DESIGN:** Models CH12/24 and CH12/24W (white color) electronic chimes. Units have 16 selectable tones and a high/medium/low volume control switch. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 8-33 VDC/FWR

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as electronic chimes for use with separately listed compatible fire alarm control units. Suitable for private mode only. For wall mount and indoor use only.

Units can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. Refer to manufacturer's Installation Manual for details.

12-18-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 14, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager